



PUBLIC NOTICE

Notice #14483-02

March 21, 2018

This notice is to inform the public that the South Carolina Department of Health and Environmental Control (DHEC) is taking public comments on a Corrective Action Plan (CAP). This CAP addresses the cleanup of soil and groundwater contamination at the facility listed below. The contamination was caused by petroleum products released from the underground storage tank system at this facility.

FACILITY: Lena Quick Stop, Highway 3, Estill, SC

APPLICANT: Midlands Environmental Consultants, Inc., 231 Dooley Road, Lexington, SC 29073

SUMMARY OF CAP: Petroleum and petroleum byproducts naturally break down over time through chemical, physical, and biological processes. These processes are called natural attenuation. **Midlands Environmental Consultants, Inc.** has submitted a CAP proposing the use of the following technologies in addition to natural attenuation to clean up the contamination.

- Pulverized Activated Carbon: Injection of a pulverized carbon product and magnesium sulfate into the specified areas of the contaminant plume will allow the carbon to adsorb petroleum based contaminants, as well as provide a substrate for indigenous bacteria to colonize and regenerate the carbon in-situ.

PUBLIC COMMENT PERIOD DEADLINE: The **deadline** for submitting written comments is **5 PM April 6, 2018**. Any interested person(s) may submit written comments concerning the cleanup to the Project Manager listed below. Please bring this notice to the attention of persons whom you know will be interested in this matter. Where there is a significant degree of public interest, DHEC will hold a public hearing.

Kathryn H. Butler
SCDHEC - UST Management Division
2600 Bull Street
Columbia SC 29201
803-898-0606

CONTACT INFORMATION: For additional information, please call the Project Manager listed above. To view a copy of the CAP, contact the Freedom of Information Office at 803-898-3882 or view it online at <http://www.scdhec.gov/Apps/Environment/PublicNotices>

Section 280.67 of the S.C. Underground Storage Tank Control Regulations (R.61-92) requires that any CAP prepared to meet the requirements of 280.66 be placed on notice for public comment.